

Title:	Hazard Management Schedule	Mandatory
		Generic
		Guidance
		Contract Specific

Hazard Management Schedule

Project Title: S278 Asda Breck Road Job No.: 00205011

Completed by: DD

Date of completion: Jan 2014

Approved by: JMc

Date of approval: Jan 2013

Ref.	Element of Design / Activity	Hazard	Persons at risk*	Design Measures taken to eliminate or reduce the hazard	Information on the Residual Risk	Date Issue Raised	Action required by [†] :
1.3, 1.7, 1.8, 1.9, 1.10, 1.16, 9.1, 9.2.	Site Wide.	Site access/egress, contact with moving vehicle/plant and unauthorised access onto site.	1 and 2	Appendix 1/13 & 1/17 specifies constraints, barrier systems, traffic management drawings required and appropriate use of Chapter 8. NCT to approve detailed TM proposals.	Traffic Management layouts to complement works programme. Principal contractor to propose suitable pedestrian barrier system and provide method statements accordingly.	Jan 2014	Principal Contractor

* Persons at Risk: (1) Construction workers (2) Members of the Public (3) Maintenance workers (4) Demolition workers

† Action by: CDM Coordinator – include in the pre-construction information / Construction Phase Plan / Health and Safety file
Principal Contractor – manage risk during the construction phase
Other Designers – take into consideration when preparing their designs

Amey

Title:	Hazard Management Schedule	Mandatory
		Generic
		Guidance
		Contract Specific

Ref.	Element of Design / Activity	Hazard	Persons at risk*	Design Measures taken to eliminate or reduce the hazard	Information on the Residual Risk	Date Issue Raised	Action required by [†] :
2.1, 5.5, 8.1, 8.7, 8.8, 9.3, 9.9, 9.10, 8.5, 8.8, 8.11, 8.13.	Highway Maintenance	Services, manual handling and health hazards.	1	The responses from Statutory Undertakers have been included in the works package. Contractor expected to comply with Manual Handling Regulations. Deep excavations to be kept to a minimum.	Principal Contractor to confirm that all the Statutory Undertakers plant locations are indicated correctly. Principal Contractor to employ mechanical lifting equipment where possible. Operatives to be fully protected by PPE and receive necessary training.	Jan 2014	Principal Contractor
9.6, 9.7, 9.8.	Finishes	Hazardous materials, noise/vibration and dust/fumes.	1	Appendix 1/9 states requirements for dust/vibration control. Dust suppression methods to be employed where possible.	Principal Contractor to provide method statements in developed Health and Safety Plan.	Jan 2014	Principal Contractor