LEGEND

SUPPLY GRILLE 4 WAY

EXTRACT GRILLE 4 WAY

NOTES:

ALL FINAL BRANCHES TO HAVE VCD

ALL GRILLES TO HAVE FLEXIBLE CONNECTIONS

ALL DUCTWORK TO BE INSULATED

ACCESS DOOR TO BE PROVIDED AT FIRE DAMPERS, BRANCHES, ADJACENT TO VCDs, VAVs, CAVs & AT DISTANCES NO GREATER THAN 6m.

FIRE DAMPER TO BE INCORPORATED IN ALL FIRE WALLS AND FLOORS IN ACCORDANCE WITH WSP FIRE STRATEGY REPORT STAGE 4, APRIL 2015.

1 205213 - VENT BLOCK A, LEVEL 3
1 : 50

Rev	Date	Description	By	Check
2	07/05/15	STAGE 4 ISSUE - UPDATE	GPB	DB
1	24/04/15	STAGE 4 ISSUE	GPB	DB

COPYRIGHT: THE COPYRIGHT OF THIS DRAWING IS VESTED IN CLANCY CONSULTING.
IT SHALL NOT BE USED WITHOUT PERMISSION BY ANYONE FOR ANY PURPOSE.
ALL DIMENSIONS TO BE CHECKED ON SITE PRIOR TO ANY WORK TO FURNISH DIMENSIONS ONLY.
ALL DIMENSIONS ARE IN MILLIMETRES UNLESS STATED OTHERWISE.
DO NOT SCALE FROM DRAWING. USE FIGURED DIMENSIONS ONLY.
DO NOT SUPPLANT WORK THAT HAS BEEN FITTED.

Revit 2014

Client: ST. JULIES CATHOLIC HIGH SCHOOL

Project: LIVERPOOL SCHOOLS INVESTMENT ST. JULIES CATHOLIC HIGH SCHOOL

Office: LIVERPOOL

Discipline: MECHANICAL | App.: BW

Title: VENTILATION DUCTWORK DISTRIBUTION STRATEGY - BLOCK A, LEVEL 3

Scale @ A0: 1 : 50 | Status: CONCEPT

clancy consulting
www.clancy.co.uk

Originator	Job Number	Discipline	Building/Zone
CCL	7/4987.1	M	-
Type	**Level**	**Drawing No.**	**Revision**
PDF_	_03_	205213	2