




- LIGHTING KEY:
- LARGE MULTI DIRECTIONAL LIGHTING
15M HIGH POLE MOUNTED LUMINAIRES
8-10 LUMINAIRE FIXTURES PER COLUMN
TO LIGHTING SPECIALISTS SPECIFICATION
 - SMALL MULTI DIRECTIONAL LIGHTING
8M HIGH POLE MOUNTED LUMINAIRES
2 LUMINAIRE FIXTURES PER COLUMN
TO LIGHTING SPECIALISTS SPECIFICATION
 - MEDIUM MULTI DIRECTIONAL LIGHTING
12M HIGH POLE MOUNTED LUMINAIRES
8-10 LUMINAIRE FIXTURES PER COLUMN
TO LIGHTING SPECIALISTS SPECIFICATION
 - 12M & 8M HIGH POLE MOUNTED
LUMINAIRES
2 LUMINAIRE FIXTURES PER COLUMN
TO LIGHTING SPECIALISTS SPECIFICATION
 - CEILING RECESSED LUMINAIRES
TO LIGHTING SPECIALISTS SPECIFICATION
 - TREE MOUNTED SPOTLIGHTS
TO LIGHTING SPECIALISTS SPECIFICATION
 - UPLIGHT WALL WASHER LUMINAIRES
TO LIGHTING SPECIALISTS SPECIFICATION
 - HANDRAIL/BALUSTRADE INTEGRATED
LUMINAIRE
TO LIGHTING SPECIALISTS SPECIFICATION
 - WALL BENCH INTEGRATED LUMINAIRE
FULLY ENCLOSED WATER TIGHT UNITS
TO LIGHTING SPECIALISTS SPECIFICATION
 - PROJECTOR LUMINAIRE UPLIGHTING
ARCHITECTURAL FRONT FACE PANELS OF
BARREL ROOF
TO LIGHTING SPECIALISTS SPECIFICATION
- LUX PLOT KEY:
- 3.0 LUX
 - 5.0 LUX
 - 7.5 LUX
 - 10.0 LUX
 - 15.0 LUX
 - 20.0 LUX
 - 30.0 LUX
 - 50.0 LUX
 - 80.0 LUX

(FOR LOCAL AUTHORITY USE)

QR Code





General Notes
LIGHTING NOTES

- THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL OTHER DISCIPLINES, DRAWINGS, SCHEDULES AND SPECIFICATIONS, LEGENDS AND STANDARD DETAILS.
- THIS DRAWING IS COPYRIGHT AND SHALL NOT BE REPRODUCED WITHOUT PERMISSION.
- DIMENSIONS GOVERN ON ALL DRAWINGS AND DETAILS. SHOULD ANY DISCREPANCIES BE FOUND WITH THIS DRAWING AND ANY ASSOCIATED DRAWINGS OR SPECIFICATIONS THIS SHOULD BE BROUGHT TO THE ATTENTION OF THE I&E BUILDING SERVICES CONSULTANT IMMEDIATELY.
- UNLESS OTHERWISE STATED ALL DIMENSIONS ARE IN MILLIMETRES.
- DO NOT SCALE FROM THIS DRAWING.
- DIMENSIONS TO BE CHECKED ON SITE BEFORE ANY WORK IS PUT IN HAND OR PREFABRICATED.
- THIS DRAWING SHOULD ONLY BE USED FOR THE SPECIFIC SERVICES INTENDED.
- THIS DRAWING SHOWS THE DESIGN INTENT ONLY. THE CONTRACTOR SHALL BE RESPONSIBLE FOR THE FULL CO-ORDINATION OF THE SERVICES INDICATED ON THIS AND ALL OTHER SERVICES DRAWINGS.
- FINAL ACCESS AND SETTING OUT OF SERVICES SHALL BE AGREED BETWEEN THE ARCHITECT AND THE CONTRACTOR.
- THE PROJECT NOTES ARE TO BE READ IN CONJUNCTION WITH ALL RELEVANT TECHNICAL SPECIFICATIONS.
- WHERE ELECTRICAL SERVICES PASS THROUGH FIRE COMPARTMENTATION CEILING VOIDS, FLOOR VOIDS AND STRUCTURAL WALLS THE CONTRACTOR SHALL SILENTLY SEAL THE OPENING WITH AN ACOUSTIC AND FIRE SEALANT APPROVED BY THE ARCHITECT.
- THE CONTRACTOR SHALL REFER TO THE ARCHITECT'S DRAWINGS FOR DETAILS OF FIRE COMPARTIMENTATION.
- FOR THE SPECIFICATION OF ALL LUMINAIRE PLEASE REFER TO THE LUMINAIRE SCHEDULE.
- THE CONTRACTOR SHALL REFER TO THE ARCHITECT'S REFLECTED CEILING PLANS AND ROOM ELEVATIONS FOR THE EXACT LOCATION OF ALL SERVICES.

No Description
SAFETY, HEALTH AND ENVIRONMENT INFORMATION
Brief details on the identified hazard and symbol referencing the unusual residual hazards / risks are listed above.

Rev	Description	Apr	Chk'd	Date
P04	D3-PLANNING	RMC	AR	10.08.20
P03	D3-PLANNING	RMC	AR	22.11.19
P02	D3-PLANNING	RMC	AR	02.10.19
P01	D3-PLANNING	RMC	AR	30.05.19



Project Title
N3967_The People's Project

Drawing Title
**EXTERNAL LIGHTING
SHEET 1**

Checked AW	Drawn JRH	Designed AR
Purpose of Issue D3- PLANNING		
Notes File Ref BMD01-BHE-ZX-ZZ-M3-E-ElectricalRevit		
Drawing No BMD01-BHE-ZX-ZX-DR-YB-0300		
Scale: A0 (841x1189) 1 : 400	Status D3	Revision No P04