
## MINI: SOIL: SURVEYS

M

MINI SOIL SURVEYS (NORTHERN) LTD. 12 Beech Walk, Leigh, Lancs. WN7 3LH Tel: (01942) 269769 Fax: (01942) 262132



**KEY PLAN** 

SITE: EVERTON ROAD LIVERPOOL

Not to Scale: diagrammatic only: all dimensions are in metres (BH. = Borehole TP. = Trial Pit)

## MINI: SOIL: SURVEYS



MINI SOIL SURVEYS (NORTHERN) LTD. 12 Beech Walk, Leigh, Lancs. WN7 3LH

Turf over brown/dark brown sand, gravel and brick rubble with some ash and cinder bands and occasional cobbles.

Disturbed sample taken 0.2 - 0.7m.

700

Weak weathered red/brown SANDSTONE

0

Turf over compact light brown sand and angular limestone gravel with some brick rubble.

Tel: (01942) 269769

Fax: (01942) 262132

Disturbed sample taken 0.1 - 0.4m.

300

Weak weathered red/brown SANDSTONE

TRIAL PIT A

**TRIAL PIT B** 

**TRIAL PITS** 

SITE: EVERTON ROAD LIVERPOOL

## MINI: SOIL: SURVEYS

W

Tel: (01942) 269769

Fax: (01942) 262132

MINI SOIL SURVEYS (NORTHERN) LTD. 12 Beech Walk, Leigh, Lancs. WN7 3LH

**TRIAL PITS** 

Turf over dark brown sandy topsoil with gravel and some cinder. 200 ' Turf over brown/dark brown sand, ash and brick rubble with cinder, gravel, some concrete and occasional timber. Red/brown occasionally dark brown sand and weathered sandstone gravel with some cinder and fine brick fragments. Disturbed sample taken 0.3 - 0.8m. Disturbed sample taken 0.3 - 0.8m. 1000-1000-**TRIAL PIT C TRIAL PIT D** 

SITE: EVERTON ROAD LIVERPOOL

# MINI SOIL SURVEYS (NORTHERN) LTD 12 Beech Walk, Leigh, Lancs. WN7 3LH

tel. 01942 269769 fax. 01942 262132

#### Site:- EVERTON ROAD LIVERPOOL

Job No. NTH 1276 Date:- 24/2/14 BH No.1 of 4

100 NO. NTTT 1270	24.	C 24/	_,	DIT 140.1 OF 4
Description	Depth	Leg	Test/ Depth	Value
urf over dark brown sandy topsoil with ash, cinder, brick rubble, mixed gravel and roots. MADE GROUND.			0.2 DS	
Veak weathered red/brown SANDSTONE.	0.40			
Refusal on sandstone.	0.65			

## MINI SOIL SURVEYS (NORTHERN) LTD

12 Beech Walk, Leigh, Lancs. WN7 3LH

#### Site:- EVERTON ROAD LIVERPOOL

**BH No.2 of 4** Job No. NTH 1276 Date: - 24/2/14

Description	Depth	Leg	Test/ Depth	Value
Turf over dark brown sandy topsoil with gravel, cinder and brick fragments. MADE GROUND.		XXXXX XXXXX	•	
Loose becoming medium dense brown/red ash, sand and fragmented brick with some cinder, sandstone fragments and fragmented concrete block. MADE GROUND.	0.30		0.3 DS	
			1.2 SPT	N = 8
Very weak weathered light brown SANDSTONE.	1.80		1.8 SPT 1.9 DS	N = 20
Refusal on sandstone.	2.10			
	1			

SPT @ 1.2m 1/2/2,2,2,2 @ 1.8m 3/4/4,7,4,5 Borehole dry.

# MINI SOIL SURVEYS (NORTHERN) LTD 12 Beech Walk, Leigh, Lancs. WN7 3LH

# tel. 01942 269769 fax. 01942 262132

#### Site:- EVERTON ROAD LIVERPOOL

Job No. NTH 1276 Date:- 24/2/14 BH No.3 of 4

300 NO. NTTT 1270	Date 24	72/14 BIT NO.3 OF 4
Description	Depth Leg	Test/ Depth Value
Turf over dark brown sandy topsoil with gravel, cinder and fine brick fragments. MADE GROUND.		
Medium dense occasionally loose brown/red sand and fragmented brick with occasional ash, concrete fragments and rare timber fragments.  MADE GROUND.	0.30	0.3 DS
		1.0 DS
		1.2 SPT N = 15
		1.8 SPT N = 8
		2.4 SPT N = 11
Refusal. Suspect sandstone.	2.80	

SPT @ 1.2m 3/3/4,5,3,3 @ 1.8m 4/2/2,2,2,2 @ 2.4m 2/2/1,2,4,4 Borehole dry.

## MINI SOIL SURVEYS (NORTHERN) LTD

12 Beech Walk, Leigh, Lancs. WN7 3LH

#### Site:- EVERTON ROAD LIVERPOOL

Job No. NTH 1276



**BH No.4 of 4** Date: - 24/2/14

JOD NO. NTH 1276	Date:-	24/2/1	ط 4 —	П NO.4 OI 4
Description	Depth Le	eg T	est/ epth	Value
Turf over loose occasionally medium dense dark brown/red ash, sand and brick rubble with some cinder, sandstone and concrete fragments, mixed gravel and rare plastic fragments. MADE GROUND.		0	).3 DS	
		1	.2 SPT	N = 8
		1	.8 SPT	N = 10
		2	2.4 SPT	N = 16
Loose occasionally very loose red/brown fine to medium SAND and highly weathered sandstone fragments. (fragmented by sampler.)	2.70 0 0 0 0 0 0 0	0.00 2 0.00 2 0.00 0 0.00 0	2.8 DS	
	ô∴. ô∴.	0.∴0 0.∴0 3	3.6 SPT	N = 15
Weak weathered light brown SANDSTONE.	3.80			
Refusal on sandstone.				

SPT @ 1.2m 4/3/3,3,1,1 @ 1.8m 2/2/1,3,3,3 @ 2.4m 2/2/1,1,9,5 @ 3.6m 1/1/0,1,3 11 Borehole dry.