


Notes

ALL DISSIMILAR MATERIALS TO BE ISOLATED BY THE USE OF PVC ISOLATING TAPE.
ALL SUPPORT MEMBERS ARE BY OTHERS UNLESS NOTED OTHERWISE.



FL10 1.5mm THICK CORTEN COPING FINISH TP
MATCH PANELS & SECURED USING SDP3-T16
5.5x32 SCREWS AT 400 CENTRES.

FL09 1.6mm THICK GALV ZED SECURED USING
FLAT HEAD SCREWS AT TOP HAT CENTRES.

FL08 70x30x1.6mm THICK GALV ANGLE SECURED
USING FLAT HEAD SCREWS AT TOP HAT
CENTRES.

BENCHMARK KSSVG25 PVC TAPE

CARRIER TO BE BED ON TWO
RUNS OF SVG 25 PVC SEAL

KINGSPAN KSHOW/P EXTRUDED MULLION
SECURED AT PANEL JOINT CENTRES & AT
MID PANEL POINT WHERE REQUIRED USING
KSA FL6 FASTENERS AT 480mm CTRS

FL01 1.6mm THK GALV TOP HAT SECURED
USING KSA FL6 FASTENERS AT 480mm
CTRS (PAIRED ACROSS FLANGES).

80mm THICK BENCHMARK CARRIER PANEL
LAID HORIZONTALLY & SECURED TO SFS
USING SD3-S16 5.5x110 SCEWS. FINISH TO
BE CONFIRMED.

LOKFOLD ALUMINIUM STANDING SEAM ROOFING
SYSTEM FINISHED PPC - COLOUR TO BE CONFIRMED.
CLIPS SECURED AT 150 & 300mm CENTRES.

SFS FRAMEWORK IS SUPPLIED
& INSTILLED BY OTHERS.

80mm THICK ADMASTER CARRIER PANEL
LAID HORIZONTALLY & SECURED TO SFS
USING FLAT HEAD Ø5.5x100 SCEWS. FINISH
TO BE CONFIRMED.

FL05 0.7mm THICK STEEL DRIP FLASHING.
FINISH TO MATCH PANELS & SECURED
USING FLAT HEAD ST STEEL SCREWS AT
STUD CENTRES.

FL06 70x70x1.6mm THICK GALV CLEADER
SECURED USING FLAT HEAD SCREWS AT
STUD CENTRES.

CAVITY FILLED USING FR RATED CANISTER
APPLIED INSULATION

+20,135 SSL

INSULATED ROOF GUTTER COMPRISING OF 0.7mm
WHITE LINER, 50mm THK PIR INSULATION & 1.2mm
THICK MEMBRANE LINED TOP LAYER. ALL SECURED
USING SD3-T15 5.5x25mm SCREWS.

FL07 1.6mm THICK GALV ZED SECURED
USING SD8-T16 5.5x25mm SCREWS AT
400 CENTRES.

KINGSPAN PANEL CARRIER CLEAT SECURED
AT 1.2m CENTRES OR EVERY OTHER STUD.

CAVITY TO BE FILLED WITH FR RATED
CANISTER APPLIED INSULATION.

AIR SEAL - 200mm WIDE BUTYL
STRIP FITTED CONTINUOUSLY
ACROSS PANEL JOINT.

SFS FRAMEWORK IS SUPPLIED
& INSTILLED BY OTHERS.

PANEL HEIGHT
HOOK CENTRES
TOP HAT LENGTH

Ø100mm UPVC DOWNPIPE TO RUN
THROUGH RAINSCREEN CAVITY &
DRAIN IN FIRST FLOOR GUTTER.



Hilbre Court Business Centre
Corporation Road, Birkenhead
Wirral CH41 3NG

Tel: 0151 649 0001
Fax: 0151 647 7088

Client
NU CONSTRUCTION Ltd.

Contract Title
CHANCERY HOUSE
LIVERPOOL

Drawing Title
CORTEN COPING DETAIL

| Rev | Date | Revisions |
|-----|------|-----------|
| - | | |

| | | | |
|---------|-----|-------|----------|
| Drawn | WBW | Date | MAR 2016 |
| Checked | | Scale | 1:5 @ A3 |

Drawing No. C683 — 031