

Notes

ALL DSSIMLAR MATERIALS TO BE ISOLATED BY THE USE OF PVC ISOLATING TAPE. ALL SUPPORT MEMBERS ARE BY OTHERS UNLESS NOTED OTHERWISE.

FL30(A) & (B) 1.6mm THICK GALV TOP HATS
TH (A) TO BE RADIUS AS NOTED & SECURED HORIZONTALLY AT 1260mm VERTICAL CENTRES.
TH (B) TO BE INSTALLED VERTICALLY AT 660mm CENTRES.
BOTH SECURED USING SD3 5.5x25mm SCREWS AT 400 CENTRES.

CARRIER TO BE BED ON TWO RUNS OF SVG 25 PVC SEAL

2 No. SKINS OF 1.6mm THICK GALVANISED STEEL SHEET SELF CURVE TO SUIT WALL RADIUS. SECURED TO STUDS & BRACKETS USING SD3 T16 5.5x25mm SCR. ALL TO CREATE AN 80mm THK INSULATE.

40mm THICK PIR INSULATION BOARD INSTALLED HORIZONTALLY & SPLIT AT 400mm CENTRES TO CREATE FACET
35/40mm THICK PIR INSULATION BOARD 600mm WIDE INSTALLED VERTICALLY BETWEEN VERTICAL TOP HATS.

+11,435 SSL

KINGSPAN KSHOM/P EXTRUDED MULLION SECURED AT PANEL JOINT CENTRES & AT MID PANEL POINT WHERE REQUIRED USING KSA FL6 FASTENERS AT 480mm CTRS

FL01 1.6mm THK GALV TOP HAT SECURED USING KSA FL6 FASTENERS AT 480mm CTRS (PAIRED ACROSS FLANGES).

FL13 1.6mm THICK CORTEN ZED BRACKET SECURED USING SX3-T16 5.5x25mm SCREWS AT 400 CENTRES.

FL14 30x28x1.6mm THICK GALV ANGLE BRACKET SECURED USING SX3-T16 5.5x25mm SCREWS AT 400 CENTRES.

1.5mm THK GALV GUTTER CW SEALED JOGGLE JOINTS.

1.5mm THK CORTEN BOX FLASHING SECURED USING No.10x25mm PAN HD SD S/S SCR AT 400mm CENTRES.

SILICONE POINT & BACKER ROD COMPATIBLE WITH CORTEN FINISH.

FL17 35x35x1.6mm THICK GALV ANG BRACKET SECURED USING SX3-T16 5.5x25mm SCREWS AT CARRIER CENTRES.

FL15 1.5mm THICK CORTEN FLASHING FINISHED TO MATCH PANELS & SECURED USING SX3-T16 5.5x25mm SCREWS AT 400 CENTRES.

FL46 0.7mm THICK STEEL CLOSER FLASHING FINISHED TO MATCH PANELS & SECURED USING SX3-T16 5.5x25mm SCREWS & RIVETS AT 400 CENTRES.

KINGSPAN KSHOM/P EXTRUDED MULLION SECURED AT PANEL JOINT CENTRES & AT MID PANEL POINT WHERE REQUIRED USING KSA FL6 FASTENERS AT 480mm CTRS

FL11 1.6mm THICK GALV ZED BRACKET SECURED USING SD8-T16 5.5x25mm SCREWS AT 400 CENTRES.

PANEL SEALED USING A GUN GRADE SEALANT

FL12 1.6mm THICK GALV ZED BRACKET SECURED USING SD3-T16 5.5x25mm SCREWS AT 400 CENTRES.

CAVITIES TO BE FILLED WITH LOOSE FILL QUILT INSULATION
100mm SQ SIDE EXIT OUTLET TO BE COUPLED WITH DOWNPIPE TO RUN INTERNALLY TO GULLY BELOW.

SEE ABOVE FOR DETAILS OF BUILT UP COMPOSITE TO GROUND FLOOR LEVEL.

FL16(A) & (B) 1.6mm THICK GALV TOP HATS SECURED TO BLOCKWORK USING TBT-6.3x32 SCREWS AT 400 CENTRES.



Hilbre Court Business Centre
Corporation Road, Birkenhead
Wirral CH41 3NG

Tel: 0151 649 0001
Fax: 0151 647 7088

Client
NU CONSTRUCTION Ltd.

Contract Title
CHANCERY HOUSE
LIVERPOOL

Drawing Title
CORTEN FIRST FLOOR
SLAB DETAIL
(BUILT UP SYSTEM)

Rev	Date	Revisions
-		

