

## Antony Swann

---

**From:** At@arbtech.co.uk  
**Sent:** 18 May 2015 16:22  
**To:** Antony Swann  
**Subject:** RE: Crown Street Liverpool

Hello Antony,

It was good to talk with you again just now. As we discussed, I feel that the new hard surfacing proposal within the RPAs of trees T1 - T9 and group G1 will not be detrimental to the trees health if the following conditions are adhered to during construction:

1. The new surfacing is built entirely above the level of the existing hard surfacing.
2. That the finished tarmac surface is porous in nature.

If you would like to have an informal chat to discuss your project please contact me on: 07703 676 216

Regards

**Alan Thompson, FdSc (Arb). M Arbor A  
Arboricultural Consultant**

07703 676 216

Arbtech Consulting Ltd

Arboricultural and Ecological Consultants

[www.arbtech.co.uk](http://www.arbtech.co.uk)

[Bat Survey](#) | [Tree Survey](#) | [Habitat Survey](#)

Important: This e-mail and any attachment, estimate or quotation is pursuant to our General Terms and Conditions ("Terms") <http://arbtech.co.uk/terms-conditions/> The Terms give details of the basis upon which we will provide our consultancy services and should be read in conjunction with any accompanying correspondence. Arbtech Consulting Limited is registered in England and Wales: 05678552. VAT: GB903660148

---

**From:** Antony Swann [Antony.Swann@mouchel.com]  
**Sent:** 15 May 2015 15:05  
**To:** At@arbtech.co.uk  
**Subject:** Crown Street Liverpool

Afternoon Alan

You did a tree survey for us in December for Crown Street Resource Centre in Liverpool. I've been on site this morning with the Contractor and he has asked if we could omit the Cellweb/ Geotextiles build up from the location of the highlighted area on the attached plan as it's proving difficult to achieve the car parking levels due to its 185mm build-up. He would ideally like to tarmac the area of which 30mm is tarmac & 70mm sub-base. As you can see by the revised plan we have omitted the car parking to this area as we couldn't get the car parking to work due to the existing constraints of the site.

Could you please give us your thoughts on if we could tarmac this area or alternatively replace the existing gravel? Thanks!

Kind Regards,

**Antony Swann**  
Architect

**Mouchel Property - Liverpool Office**

Exchange Station, Tithebarn Street, Liverpool, L2 2QP

T: 0151 243 9950 | E: [Antony.Swann@mouchel.com](mailto:Antony.Swann@mouchel.com) | W: [www.mouchel.com](http://www.mouchel.com) | Visit our [Flickr](#) page



Mouchel Limited (Mouchel) is registered in England and Wales with registered number 01686040 at Export House, Cawsey Way, Woking, Surrey, UK, GU21 6QX. The information in this e-mail is confidential and may be legally privileged. It is intended solely for the addressee. Access to this email by anyone else is unauthorised. Any views or opinions expressed in this e-mail may be solely those of the author and are not necessarily those of Mouchel. No contracts may be concluded on behalf of Mouchel by means of email communications. Mouchel reserves the right to monitor and intercept emails sent and received on our network.