

House Type B

Lifetime Homes Compliance for all proposed residential development



Developer's checklist (to help in the assessment of an application)

Date: 7th January 2015
Development details (address, planning application reference): Park Avenue off Sefton Park
Schedule completed by: A Granby- Calderpeel fgp

Please:

- Complete the development details above,
- Check your proposals against the published standards at www.lifetimehomes.org.uk and the July 2010 edition and Lifetime Homes Design Guide (2011).
- Clearly verify compliance / non-compliance in the yes/no/ na column of the schedule against each specification. Provide valid justification if answered no.
- Note; completed schedule will form part of the assessment of the application, and will be referred to in a relevant planning condition.

Schedule summarising Lifetime Home Criteria & specifications

NB. LTH specifications exceeding Approved Document M (ADM) Building regulation requirements and for clarity included within the requirements below. See also LTH/ADM comparison at: <http://www.lifetimehomes.org.uk/pages/lifetime-homes-and-part-m.html>

Parking, Approaches and Main Entrances (criteria 1-6)

Std no.	LTH criteria	Compliance (to be completed by applicant/ agent)
1a	'On plot' (non communal) parking. Where there is car parking within a dwelling's individual plot (or title), at least one space should be capable of enlargement to 3300mm minimum width.	Scheme complies/ will comply? (State below yes/no/ n.a.)
	LTH/ ADM requirement: 2400mm wide parking space + a further 900mm access path adjacent to it (and level with it) – or provision to enlarge at later date (e.g. adjacent grass verge).	1a. Yes
1b)	Communal or shared parking. Where this type of parking is provided, it should include 3300mm wide spaces.	Scheme complies/ will comply? (State below yes/no/ n.a.)
	One space, min 3300mm wide x 4800mm deep adjacent (or close) to each block's entrance/lift core, (in addition to any parking provided for wheelchair standard housing). Maintain access route (1200mm min wide) between parking and entrance/ lift core.	N/A
2.	Approach to dwelling from parking. The distance from the car parking space to the dwelling entrance (or relevant block entrance/ lift core) should be kept to a minimum and be level or gently sloping. The distance from visitors parking to relevant entrances should be as short as practicable, and be level or gently sloping.	Scheme complies/ will comply? (State below yes/no/ n.a.) 2. Yes

3.	<p>Approach to all entrances The principle access route to <u>all</u> entrances needs to meet ADM 'level' or 'ramped' approach requirements.</p> <ul style="list-style-type: none"> Distance from the car parking to the home to be kept to a minimum. Paths to be firm reasonably smooth & slip free, 900mm min. width within curtilage/ 1200mm min. for communal use. ADM 'stepped' approach (6.16 – 6.17), only acceptable as a secondary alternative access route in addition to the principle route (to any entrance). 	3. Yes
----	---	--------

Entrances, doorways & communal stairs / lifts (Criteria 4 - 6)

<div>4.</div>	<div>Entrances should:</div> <div><div>4a) be illuminated – provide diffused luminaries</div><div>4b) have level access over the threshold - Level threshold: max 15mm up-stand)</div><div>4c) have effective clear opening widths and leading edge to the door handle side</div></div> <div>Main entrances</div> <table><tr><td>Communal entrance doors at right angles to an access route less than 1500mm wide (1200mm min) (LTH/ADM)</td><td>825 mm min effective clear width</td></tr><tr><td>All other dwelling and communal entrance doors, either straight on from access route or at right angles to one at least 1500mm wide</td><td>800 mm min effective clear width* (more than ADM)</td></tr></table> <div><div>4d) have adequate weather protection at main entrances:</div><div><div>• Individual dwellings = 900mm typical depth (600mm min).</div><div>• Communal dwellings = 1200mm typical depth (900mm min).</div></div><div>Width to exceed door set + any controls. Additional cover/</div></div>	Communal entrance doors at right angles to an access route less than 1500mm wide (1200mm min) (LTH/ADM)	825 mm min effective clear width	All other dwelling and communal entrance doors, either straight on from access route or at right angles to one at least 1500mm wide	800 mm min effective clear width* (more than ADM)	<div>Scheme complies/ will comply? (State below yes/no/ n.a.)</div> <div><div>4a. Yes</div><div>4b. Yes</div><div>4c. Yes</div></div> <div>4d. Yes</div>
Communal entrance doors at right angles to an access route less than 1500mm wide (1200mm min) (LTH/ADM)	825 mm min effective clear width					
All other dwelling and communal entrance doors, either straight on from access route or at right angles to one at least 1500mm wide	800 mm min effective clear width* (more than ADM)					

	<p>protection may be needed on exposed sites.</p> <p>4e) have a level external landing (dims. clear of any door swings):</p> <ul style="list-style-type: none"> Individual dwellings (LTH/ADM) = 1200x1200 min Communal dwellings = 1500 x 1500 min 	4e. Yes
--	---	---------

5a	<p>Communal stairs</p> <p>Principal stairs should provide easy access (regardless of whether lift is provided)</p>	Scheme complies/ will comply? (State below yes/no/ n.a.)
	<p>LTH / ADM requirements: 170mm max rise & 250mm max going, handrails 900mm above nosings & extend (level) 300mm beyond top and bottom step, visual contrast on nosings, no open risers).</p> <p>LTH additional requirements to ADM: <u>All</u> communal stairs within a block to achieve this specification - and regardless of whether or not a lift is provided.</p>	N/A
5b	<p>Communal Lifts</p> <p>Where homes are reached by a lift, it should be fully accessible.</p> <p>Lifts also to meet other LTH/ ADM (including clear landings 1500mm x 1500mm)</p> <p>Minimum internal lift car size to be 1100mm x 1400mm</p>	<p>Scheme complies/ will comply? (State below yes/no/ n.a.)</p> <p>N/A</p>
6.	<p>Internal doorways, hallways & landings</p> <p>Movement should be as convenient to widest range of people. Generally narrower hallways & landings will need wider doorways in their side walls.</p> <p>Minimum widths below apply to every storey within a dwelling (ADM only relate to the entrance level).</p> <p>Hallway/ corridor min widths</p> <p>900mm within dwelling /1200mm in communal area (may reduce to 750mm/1050mm at pinch point/s, but <u>not</u> opposite/ adjacent to doorways.</p>	<p>Scheme complies/ will comply? (State below yes/no/ n.a.)</p> <p>6. Yes</p>

	<p>Effective clear opening widths to be as follows:</p> <table border="1"> <thead> <tr> <th>Direction/ width of approach (hallway/ landing)</th><th>Internal dwelling doors</th><th>Com'nal doors (appr'ch)</th></tr> </thead> <tbody> <tr> <td>Straight on without turn or oblique approach (LTH/ADM)</td><td>750 mm</td><td>800 mm</td></tr> <tr> <td>At right angles to corridor/landing at least 1500 wide</td><td>N/A</td><td>800 mm</td></tr> <tr> <td>At right angles to hallway/ corridor/ landing at least 1200mm wide</td><td>750</td><td>825</td></tr> <tr> <td>At right angles to hallway/ landing at least 1050 wide</td><td>775</td><td>N/A</td></tr> <tr> <td>At right angles to corridor/ landing less than 1050mm wide (900min width as above).</td><td>900</td><td>N/A</td></tr> </tbody> </table>	Direction/ width of approach (hallway/ landing)	Internal dwelling doors	Com'nal doors (appr'ch)	Straight on without turn or oblique approach (LTH/ADM)	750 mm	800 mm	At right angles to corridor/landing at least 1500 wide	N/A	800 mm	At right angles to hallway/ corridor/ landing at least 1200mm wide	750	825	At right angles to hallway/ landing at least 1050 wide	775	N/A	At right angles to corridor/ landing less than 1050mm wide (900min width as above).	900	N/A	6. Yes
Direction/ width of approach (hallway/ landing)	Internal dwelling doors	Com'nal doors (appr'ch)																		
Straight on without turn or oblique approach (LTH/ADM)	750 mm	800 mm																		
At right angles to corridor/landing at least 1500 wide	N/A	800 mm																		
At right angles to hallway/ corridor/ landing at least 1200mm wide	750	825																		
At right angles to hallway/ landing at least 1050 wide	775	N/A																		
At right angles to corridor/ landing less than 1050mm wide (900min width as above).	900	N/A																		

Circulation space in the main rooms (criteria 7-9)

7.	<p>Circulation Space.</p> <p>There should be space for turning a wheelchair in dining areas and living rooms and basic circulation space for wheelchair users elsewhere.</p> <p>Living & dining rooms/ areas capable of either:</p> <ul style="list-style-type: none"> 1500mm diameter clear turning circle, or 1700mm x 1400mm turning ellipse. 750 clear width between items of furniture where needed for essential circulation. <p>Occasional items of furniture (e.g coffee/ side tables) can be shown on layout plans as being within or overlapping the turning zones.</p> <p>Kitchens (preferably at entrance level): clear width of 1200mm between unit fronts/ appliances (for entire length) and fixed obstruction opposite (e.g. fittings or walls).</p> <p>Main bedroom needs clear space around bed: 750mm wide to both sides and foot of a standard sized double bed.</p> <p>Other bedrooms: 750mm clear space to one side of the bed + 750mm at its foot, if access is needed e.g. to approach window (see Criterion 15). Layouts can show</p>	<p>Scheme complies/ will comply? (State below yes/no/ n.a.)</p> <p>Yes</p> <p>Yes</p> <p>Yes</p> <p>Yes</p>
-----------	---	---

11.	<ul style="list-style-type: none"> i) A centre line between 400mm – 500mm from an adjacent wall. ii) A flush control located to the side of the cistern furthers away from the adjacent wall. iii) An approach zone extending at least <ul style="list-style-type: none"> • 350mm from the WC's centre-line towards the adjacent wall, • 1000mm from the WC's centre-line on the other side. • 1100mm forward from the front rim of the WC • 500mm back from the front rim of the WC for a width of 1000mm from the WC's centre-line. 	Yes- choice of fitting to be determined.
	<ul style="list-style-type: none"> 1. A basin on the wall adjacent to the WC or cistern should: <ul style="list-style-type: none"> • not project into the approach zone by more than 200mm, • have a clear approach zone of 1100mm (from any obstruction under it) 	Yes
	<ul style="list-style-type: none"> 2. Floor drainage (unless provided elsewhere at entrance level) for an accessible floor level shower, located as far from the doorway as practicable and floor construction with shallow falls for drainage, or which allows easy installation of future laid to fall surface. <p>Note: These layout requirements can be achieved in a variety of ways. 1450mm x 1900mm over-all compartment size will enable increased choice of fittings.</p>	Provided at entrance level
	<ul style="list-style-type: none"> 3. Outward opening door needed to meet Approved Document M (if it's the only accessible entrance level WC in the dwelling). 	N/A
	<p>WC and bathroom Walls</p> <p>Walls in all bathrooms and WCs should be capable of firm fixing and support of adaptations such as handrails.</p> <p>Provide for adequate fixing and support for (future) grab rails onto walls at any point within 300mm and 1800mm from the floor.</p>	Yes- construction detailing to show correct wall build-up

Stairs & lifts (within dwellings), hoists & bathroom (criteria 12- 14)

12.	Stairs and potential through-floor lift.	Scheme complies/ will
-----	--	-----------------------

	<p>and bathroom.</p> <p>The structure above ceilings of a main (twin or double) bedroom, and bathroom, should be capable of supporting (or adaptation to support) future installation of single point hoists above the bed, bath and WC.</p> <p>The bedroom & bathroom (meeting Criterion 14) should:</p> <ul style="list-style-type: none"> • be on the same storey level • (unless at entrance level) have potential for access via the through floor lift (Criterion 12); <p>be designed / located to provide a reasonable route between them, which should not pass through any living/ habitable room/ area.</p>	<p>Yes- construction detailing to incorporate this</p>
14.	<p>Bathrooms</p> <p>An accessible bathroom, providing ease of access should be provided on the same storey as a main bedroom.</p> <p>An accessible bathroom, giving ease of access, should be provided</p> <ul style="list-style-type: none"> • close to a main (double or twin) bedroom, • at entrance level, or on a level with potential for access by a through floor lift (Criterion 12b) • with an outward opening door - if bathroom contains the only accessible entrance level WC (ADM requirement) • with the facilities listed (1-5) below. <p>Note: an Internal footprint of 2100mm x 2100mm increases flexibility and choice of layout, fittings etc.</p> <p>1. A WC with:</p> <ol style="list-style-type: none"> i) A centre line between 400mm – 500mm from an adjacent wall. ii) A flush control located to the side of the cistern furthest away from the adjacent wall. iii) An approach zone extending at least <ul style="list-style-type: none"> • 350mm from the WC's centre-line towards the adjacent wall, • 1000mm from the WC's centre-line on the other side. • 1100mm forward from the front rim of the WC 500mm back from the front rim of the WC for a width of 1000mm from the WC's centre-line. <p>2. A basin on the wall adjacent to the WC or cistern should:</p> <ul style="list-style-type: none"> • not project into the approach zone by more than 	<p>Yes- choice of fitting to be determined.</p> <p>Yes En-Suite in Bedroom 1 Suitable</p>

	<p>200mm and have a clear approach zone of 1100mm (from any obstruction under it).</p> <p>3. A bath <u>or</u> accessible floor level shower</p> <ul style="list-style-type: none"> • bath to have a 1100mm x 700mm clear zone alongside (can overlap with approach zone to WC and/ or basin), <u>or</u> • shower to have a clear 1500mm diameter, or 1700mm x 1400mm elliptical, clear manoeuvring zone. <p>NB. Where both a bath and accessible shower are provided from the outset, 1000mm x 1000mm min clear floor space is needed for showering.</p> <p>4. Floor drainage for an accessible floor level shower (unless provided elsewhere in the dwelling), with:</p> <ul style="list-style-type: none"> • floor construction providing shallow falls to drainage, or simple laid-to-fall provision in the future; • drainage, which if capped for future use, may be located under a bath; <p>5. If future bath removal for an accessible shower is provided for, ensure potential for a clear 1500mm diameter/1700mm x 1400mm elliptical manoeuvring zone.</p>	Yes En-Suite in Bedroom 1 Suitable
--	--	------------------------------------

Windows and service controls

15.	<p>Glazing and window handle heights</p> <p>Windows in principle living space should allow people to see out when seated. At least 1 opening light in each habitable room should be approachable and useable by a wide range of people – including those with restricted movement and reach.</p> <p>Principle window in main living room/ space:</p> <table><tr><td>Principle window (or glazed door if in lieu):</td><td>Glazing to begin 800mm from floor or lower. Must be easy to open/ operate</td></tr><tr><td>Any full width transom/ cill within field of vision (normally 1700mm of floor)</td><td>At least 400mm in height away from any other transom/ balcony balustrade.</td></tr></table>	Principle window (or glazed door if in lieu):	Glazing to begin 800mm from floor or lower. Must be easy to open/ operate	Any full width transom/ cill within field of vision (normally 1700mm of floor)	At least 400mm in height away from any other transom/ balcony balustrade.	<p>Scheme complies/ will comply? (State below yes/no/ n.a.)</p> <p>Yes</p>
Principle window (or glazed door if in lieu):	Glazing to begin 800mm from floor or lower. Must be easy to open/ operate					
Any full width transom/ cill within field of vision (normally 1700mm of floor)	At least 400mm in height away from any other transom/ balcony balustrade.					

	<p>All habitable rooms:</p> <table><tr><td>Approach route to a window (i.e. at least one in each room).</td><td>Potential for 750mm wide route for wheelchair user. Does <u>not</u> apply to kitchen/ bathrooms with a single window beyond fittings/ units.</td></tr><tr><td>Handles/ controls to an opening light to this window</td><td>No higher than 1200mm from floor. <u>Does</u> apply to kitchen & bathrooms with a single window beyond fittings/ units.</td></tr></table>	Approach route to a window (i.e. at least one in each room).	Potential for 750mm wide route for wheelchair user. Does <u>not</u> apply to kitchen/ bathrooms with a single window beyond fittings/ units.	Handles/ controls to an opening light to this window	No higher than 1200mm from floor. <u>Does</u> apply to kitchen & bathrooms with a single window beyond fittings/ units.	<p>Yes</p> <p>Yes- construction detailing to incorporate this</p>
Approach route to a window (i.e. at least one in each room).	Potential for 750mm wide route for wheelchair user. Does <u>not</u> apply to kitchen/ bathrooms with a single window beyond fittings/ units.					
Handles/ controls to an opening light to this window	No higher than 1200mm from floor. <u>Does</u> apply to kitchen & bathrooms with a single window beyond fittings/ units.					
16.	<p>Location of service controls</p> <p>Should be within a band of 450 to 1200mm from the floor, and at least 300mm from any internal room corner.</p> <p>All service & ventilation controls: within a band of 450 to 1200mm from the floor, and at least 300mm from any internal room corner (if needed to be operated or read on a frequent basis, or in an emergency; see examples listed in the standard).</p>	<p>Scheme complies/ will comply? (State below yes/no/ n.a.)</p> <p>Yes- construction detailing to incorporate this</p>				