



PROPOSED SECTION
(1:50)

Wall construction is to consist of 15mm 10kg wallboard on dabs to receive a 5m skim coat finish, 100mm Thermolite Shield (3.5KN) block inner leaf, 90mm cavity fully filled with Crown Dritherm 32 insulation, with brickwork to match existing, all to achieve a minimum 'U' value of 0.3w/m.sq.k

C35 grade concrete strip footing to be a minimum 250mm thick and is to be to a depth to suit local ground conditions and to the satisfaction of the Local Authority Building Inspector.

115 H 1388

01 JUN 2015