


Curtins Consulting Ltd		Page 1
Curtins House Columbus Quay Riverside Drive Liverpool L3 4DB	SFX College Liverpool	
Date 12-11-2014 File Proposed drainage systems	Designed by J. Poole Checked by A. O'Neill	
Micro Drainage	Network 2014.1.1	

STORM SEWER DESIGN by the Modified Rational Method

Design Criteria for Storm - science bk system 2

Pipe Sizes STANDARD Manhole Sizes STANDARD

FSR Rainfall Model - England and Wales

Return Period (years)	2	Add Flow / Climate Change (%)	0
M5-60 (mm)	19.200	Minimum Backdrop Height (m)	0.200
Ratio R	0.400	Maximum Backdrop Height (m)	1.500
Maximum Rainfall (mm/hr)	50	Min Design Depth for Optimisation (m)	1.200
Maximum Time of Concentration (mins)	30	Min Vel for Auto Design only (m/s)	1.00
Foul Sewage (l/s/ha)	0.000	Min Slope for Optimisation (1:X)	500
Volumetric Runoff Coeff.	0.750		

Designed with Level Soffits




Time Area Diagram for Storm - science bk system 2

Time (mins)	Area (ha)	Time (mins)	Area (ha)
0-4	0.011	4-8	0.003

Total Area Contributing (ha) = 0.014

Total Pipe Volume (m³) = 0.266

Network Design Table for Storm - science bk system 2


PN	Length (m)	Fall (m)	Slope (1:X)	I.Area (ha)	T.E. (mins)	Base Flow (l/s)	k (mm)	HYD SECT	DIA (mm)	Auto Design
S1.000	12.830	0.330	38.9	0.000	5.00	1.1	0.060	o	100	
S2.000	12.487	0.470	26.6	0.014	5.00	5.1	0.060	o	100	
S1.001	3.777	0.180	21.0	0.000	0.00	0.0	0.060	o	150	

Network Results Table

PN	Rain (mm/hr)	T.C. (mins)	US/IL (m)	Σ I.Area (ha)	Σ Base Flow (l/s)	Foul (l/s)	Add Flow (l/s)	Vel (m/s)	Cap (l/s)	Flow (l/s)
S1.000	50.00	5.13	81.100	0.000	1.1	0.0	0.0	1.60	12.6	1.1
S2.000	50.00	5.11	81.240	0.014	5.1	0.0	0.0	1.95	15.3	7.0
S1.001	50.00	5.16	80.720	0.014	6.2	0.0	0.0	2.86	50.5	8.1

Free Flowing Outfall Details for Storm - science bk system 2

Outfall Pipe Number	Outfall Name	C. Level (m)	I. Level (m)	Min I. Level (m)	D,L (mm)	W (mm)
S1.001	S	80.980	80.540	80.010	1200	0


Curtins Consulting Ltd		Page 2
Curtins House Columbus Quay Riverside Drive Liverpool L3 4DB	SFX College Liverpool	
Date 12-11-2014	Designed by J. Poole	
File Proposed drainage systems	Checked by A. O'Neill	
Micro Drainage	Network 2014.1.1	

Simulation Criteria for Storm - science bk system 2

Volumetric Runoff Coeff	0.750	Additional Flow - % of Total Flow	0.000
Areal Reduction Factor	1.000	MADD Factor * 10m ³ /ha Storage	2.000
Hot Start (mins)	0	Inlet Coefficient	0.800
Hot Start Level (mm)	0	Flow per Person per Day (l/per/day)	0.000
Manhole Headloss Coeff (Global)	0.500	Run Time (mins)	60
Foul Sewage per hectare (l/s)	0.000	Output Interval (mins)	1
Number of Input Hydrographs	0	Number of Offline Controls	0
Number of Online Controls	0	Number of Storage Structures	0
		Number of Time/Area Diagrams	0
		Number of Real Time Controls	0

Synthetic Rainfall Details

Rainfall Model	FSR	Profile Type	Summer
Return Period (years)	2	Cv (Summer)	0.750
Region	England and Wales	Cv (Winter)	0.840
M5-60 (mm)	19.200	Storm Duration (mins)	30
Ratio R	0.400		

Curtins Consulting Ltd		Page 3
Curtins House Columbus Quay Riverside Drive Liverpool L3 4DB	SFX College Liverpool	
Date 12-11-2014	Designed by J. Poole	
File Proposed drainage systems	Checked by A. O'Neill	
Micro Drainage	Network 2014.1.1	

Summary of Critical Results by Maximum Level (Rank 1) for Storm - science bk system 2

Simulation Criteria

Areal Reduction Factor 1.000 Additional Flow - % of Total Flow 0.000
 Hot Start (mins) 0 MADD Factor * 10m³/ha Storage 2.000
 Hot Start Level (mm) 0 Inlet Coefficient 0.800
 Manhole Headloss Coeff (Global) 0.500 Flow per Person per Day (l/per/day) 0.000
 Foul Sewage per hectare (l/s) 0.000
 Number of Input Hydrographs 0 Number of Offline Controls 0 Number of Time/Area Diagrams 0
 Number of Online Controls 0 Number of Storage Structures 0 Number of Real Time Controls 0

Synthetic Rainfall Details


Rainfall Model FSR M5-60 (mm) 19.200 Cv (Summer) 0.750
 Region England and Wales Ratio R 0.400 Cv (Winter) 0.840

Margin for Flood Risk Warning (mm) 300.0 DVD Status OFF
 Analysis Timestep Fine Inertia Status OFF
 DTS Status ON

Profile(s) Summer and Winter
 Duration(s) (mins) 15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960,
 1440, 2160, 2880
 Return Period(s) (years) 1, 10, 100
 Climate Change (%) 0, 20, 20

PN	Storm	Return Period	Climate Change	First X Surcharge	First Y Flood	First Z Overflow	O/F Act.	Lvl Exc.
S1.000	30 Summer	100	+20%					
S2.000	15 Winter	100	+20%					
S1.001	15 Winter	100	+20%					

PN	US/MH Name	Water		Flooded		Pipe		Status
		Level (m)	Surch'd Depth (m)	Volume (m ³)	Flow / Cap. (l/s)	O'flow (l/s)	Flow (l/s)	
S1.000	S1	81.121	-0.079	0.000	0.10	0.0	1.1	OK
S2.000	S2	81.313	-0.027	0.000	0.88	0.0	12.2	OK
S1.001	S3	80.795	-0.075	0.000	0.50	0.0	13.2	OK

Curtins Consulting Ltd		Page 4
Curtins House Columbus Quay Riverside Drive Liverpool L3 4DB	SFX College Liverpool	
Date 12-11-2014	Designed by J. Poole	
File Proposed drainage systems	Checked by A. O'Neill	
Micro Drainage	Network 2014.1.1	

Design Audit Report for Storm - science bk system 2

```

Filename      T:\LI1195A St Francis Xavier's College\Calculations
               \Microdrainage\Proposed drainage systems
               03-03-2015.mdx
Network Name   Storm - science bk system 2
Date Audited   06/03/2015 15:40
Pipes          3
Current Network Slope (1:X) 32.6
Storms Used (mins) 15min Summer, 30min Summer, 60min Summer, 120min
                  Summer, 180min Summer, 240min Summer, 360min Summer,
                  480min Summer, 600min Summer, 720min Summer, 960min
                  Summer, 1440min Summer, 2160min Summer, 2880min
                  Summer, 15min Winter, 30min Winter, 60min Winter,
                  120min Winter, 180min Winter, 240min Winter, 360min
                  Winter, 480min Winter, 600min Winter, 720min Winter,
                  960min Winter, 1440min Winter, 2160min Winter,
                  2880min Winter

```

Audit	Failures	Status
Manhole Sizes	2	Failed
Surcharge	0	Passed
Flood	0	Passed
Storage	0	Passed
Pipe Diameters	2	Failed
Pipe Lengths	0	Passed
Coordinate Accuracy	0	Passed
Cover Levels	1	Failed
Backdrops	0	Passed
Full Bore Velocity	0	Passed
Proportional Velocity	1	Failed
Crossings/Conflicts	0	Passed
Manhole Headloss	1	Failed
ICP Audit	0	Not Run

Manhole Size Audit

The following Manhole sizes are smaller than those specified.

US/MH Name	PN	US/MH Dia/Len (mm)	US/MH Width (mm)	Min Dia/Len (mm)	Min Width (mm)
S 1	S 1.000	1000	0	1050	0
S 2	S 2.000	1000	0	1050	0

Surcharge Audit


No pipes exceeded the 20 mm surcharge limit for the 10 year +20% climate change storm.

Flood Audit

No pipes flood for the 100 year +20% climate change storm.

Storage Audit

Storage Volume is at typical design values.

Curtins Consulting Ltd		Page 5
Curtins House Columbus Quay Riverside Drive Liverpool L3 4DB	SFX College Liverpool	
Date 12-11-2014	Designed by J. Poole	
File Proposed drainage systems	Checked by A. O'Neill	
Micro Drainage	Network 2014.1.1	

Pipe Diameter Audit

The following pipes have diameters less than 150 mm.

PN	Diameter (mm)
S1.000	100
S2.000	100

Pipe Length Audit

All pipe lengths are ≤ 100.000 m.

Coordinate Accuracy Audit

All pipe lengths are within 1.000 m of coordinates.

Upstream Cover Level Audit

All pipes have Upstream Cover Depths within the range 0.500-6.000 m.

Downstream Cover Level Audit

The following pipes have Downstream Cover Depths outside of the range 0.500-6.000 m.

PN	DSIL (m)	Diameter (mm)	DSCL (m)	Depth (m)
S1.001	80.540	150	80.980	0.290

Backdrop Audit

All backdrops are within the range 0.200-1.500m.

Full Bore Velocity Audit

All pipes have Full Bore Velocity within the range 1.00-3.00 m/s.

Proportional Velocity Audit

The following pipes have Proportional Velocity outside of the range 1.00-3.00 m/s for the 1 year +0% climate change storm.


PN	Storm (mins)	Velocity (m/s)
S1.000	1440min Winter	0.94

Crossings / Conflicts Audit

The following filter settings were used to determine the crossings and conflicts.

Vertical Separation (m): 0.500
Horizontal Separation (m): 0.500
Networks included: Storm - car park, Storm - science bk system 1, Storm - sports hall, Storm - science bk system 2
Networks excluded:

No crossings or conflicts were located for the current network based on the settings above.

Curtins Consulting Ltd		Page 6
Curtins House Columbus Quay Riverside Drive Liverpool L3 4DB	SFX College Liverpool	
Date 12-11-2014 File Proposed drainage systems	Designed by J. Poole Checked by A. O'Neill	
Micro Drainage	Network 2014.1.1	

Manhole Headloss Audit

The following manholes may have insufficient headloss.

PN	USMH	Angle (degrees)	Headloss	Recommended Value
S1.001	S3	90.6	0.500	1.200

Interim Code of Practice

The Interim Code of Practice Audit was not completed by user request